

Xing Liu

Chair Risk and Resilience of Complex Systems,
Laboratoire Génie Industriel,
CentraleSupélec,
Université Paris-Saclay 3 Rue Joliot Curie,
Gif-sur-Yvette 91190, France

Yi-Ping Fang¹

Chair Risk and Resilience of Complex Systems,
Laboratoire Génie Industriel,
CentraleSupélec,
Université Paris-Saclay 3 Rue Joliot Curie,
Gif-sur-Yvette 91190, France
e-mail: yiping.fang@centralesupelec.fr

Elisa Ferrario

Research Center for Integrated Disaster Risk
Management (CIGIDEN),
ANID/FONDAP/15110017 Avenida,
Santiago, Vicuña Mackenna 4860, Chile
e-mail: elisa.ferrario@cigiden.cl

Enrico Zio

Centre for Research on Risk and Crises (CRC),
Mines ParisTech Sophia Antipolis,
PSL Research University,
Sophia, Antipolis 06904, France;
Dipartimento di Energia,
Politecnico di Milano,
Via Ponzio 34/3,
Milano 20133, Italy
e-mail: enrico.zio@polimi.it

Resilience Assessment and Importance Measure for Interdependent Critical Infrastructures

Based upon a novel control-based dynamic modeling framework, this paper proposes two new indicators, i.e., resilience by mitigation and resilience by recovery, for the resilience analysis of interdependent critical infrastructures (ICIs) under disruptions. The former is built from the protection activities before and during the mitigation phase of a disruptive event, and the latter is the result of the restoration efforts, which take place at the recovery phase. The total resilience of ICIs combines both of these two aspects by taking into account the preferences of the decision makers. We demonstrate the applicability of the proposed modeling framework and metrics in a case study involving ICIs made of a power grid and a gas distribution system. Owing to the new resilience indicators, the priorities of subsystems and links within ICIs at different phases can be ranked; therefore, different resilience strategies at different phases of disruptive events are compared. The results show that proposed metrics can be used by stakeholders of ICIs on improving the effectiveness of system protection measurements. [DOI: 10.1115/1.4051196]

Keywords: critical infrastructure, system resilience, resilience metrics, dynamic modeling, model predictive control, importance measure, global sensitivity analysis

1 Introduction

Critical infrastructures (CIs) are complex systems that provide essential commodities, e.g., energy, natural gas, and water, and services, e.g., telecommunication, banking, and healthcare, for the welfare of modern society and life quality of people. These CIs are exposed to various types of hazards, e.g., cyber incidents, natural disasters, technical failures, and acts of terrorism [1–3].

With the increasing complexity of the system functions, physical and functional dependencies among diverse CIs are simultaneously growing. These dependency relationships not only improve the operation efficiency of interdependent CIs (ICIs) but also increase system vulnerability, e.g., provoking cascading failures, which is the situation where an initial failure originated in one CI propagates to other CIs and finally results in efficiency reduction, function loss, or destruction of the entire system-of-systems [4–7]. In recent years, diverse severe disruptive events occurred to ICIs around the world and caused immense economic losses and serious casualties, e.g., 9/11 terrorist attack, 2003 country-wide blackout in Italy, 2010 Chilean earthquake and tsunami, 2011 Tohoku earthquake in Japan, and 2017 Harvey hurricane in North America. Facing these catastrophic events, great emphasis has been placed on studies of system resilience [8–10].

Many definitions of system resilience have been proposed from various perspectives [11]. Although there is still vagueness regarding the concept of system resilience, its two main aspects are universally recognized: (1) the resistance capacity, or the complement of vulnerability, which is the capacity of the system to maintain the nominal operations and mitigate the negative impacts

of disruptions and (2) the recovery capacity, or recoverability, which is the capacity of a system to bound back to the operational state following a risk source or an adverse event. Therefore, we define the system resilience for ICIs as the capacities of a system to resist to and to recover from disruptive events.

In order to enable the development of resilient systems, many system resilience metrics have been proposed [11,12]. Relying on the application of interest, the system resilience metrics could be classified according to different criteria, such as deterministic/probabilistic, dynamic/static, and/or integration-based/ratio-based [13,14]. One classical resilience metric is an integration-based method introduced in Ref. [15]. This method takes into account both the magnitude and duration of deviation of actual system performance from targeted system performance during a disruptive event. It is effective to assess and compare system resilience in different situations, e.g., system resilience design, system resilience improvement, system resilience examination, and inspire the development of other resilience assessment and analysis approaches [14]. For example, Ouyang et al. [16] introduced a probabilistic and static annual resilience measure, which provides a statistical result of estimated system resilience under multiple potential disruptions within a suitable length of time. Fang et al. [17] proposed a dynamic resilience metric that takes into account the lowest level of system performance and is able to monitor the evolution of system resilience at each time-step. In the context of ICIs, Nan and Sansavini [18] presented an integrated metric for interdependent system resilience quantification that considers multiple phases of disruptive events. Kong and Simonovic [19] proposed a probabilistic metric based on the expansion of a single hazard deterministic resilience model to multiple hazard scenarios.

Unlike ecological systems, whose resilience is an inherent and spontaneous feature, the resilience of engineering systems, e.g.,

¹Corresponding author.

Manuscript received November 27, 2020; final manuscript received May 12, 2021; published online June 17, 2021. Editor: Bilal M. Ayyub.

ICIs, is the result of appropriate protection activities, i.e., planning and resource allocation [11,20]. The protection activities are implemented in different phases during the disruptive events, for different purposes and executed by different operators [21]. Before the onset of an adverse event or activated at the beginning of the failure propagation phase, i.e., the mitigation phase, prevent preparedness or mitigation activities are arranged to minimize the impacts of the disruption and extenuate the consequences of failure [22], such as enhancing the strength of elements, implementing redundancies, adjusting system topology, and other self-healing mechanisms [16]. Recovery activities are postevent measures, such as repairing malfunctioned elements, replacing damaged elements, and retrofitting structures. They are implemented after the disruptive event, sometimes when system performance reaches a stable disrupted level, such as repair or replacement of failed components, retrofitting, and reconstruction [23,24].

Many existing works of system resilience focus on the recovery aspect [11,25,26]. Although some resilience analysis and measurement approaches attempt to include the entire failure-recovery process of the disturbed system, few of them differentiate the contributions of mitigation activities and recovery activities. In fact, there is the necessity to measure both aspects of system resilience as the results of resilience assessment affect the effectiveness of resilience improvement strategies. For example, resilience metric is combined into the importance measure approach to prioritize the system elements [17]. However, the priorities of important system elements and key activities affecting system resilience may evolve during the disruptive event. For example, failure mitigation of a nuclear power plant within an energy system should have very high priority, as its failure leads to severe consequences, but in the recovery phase, once the core components are well protected, the less prioritized components in the first phase become important, i.e., the electrical links connected to users also should be highly prioritized, in order to resume electricity supply rapidly. Nevertheless, with the current system resilience assessments, it is difficult to capture the change on the criticality of system elements and to provide specific insights on resilience actions in the different phases of a disruptive event.

To address the above issue, this paper proposes generic resilience metrics, which highlights the contributions of both mitigation and recovery aspects. Taking into account the characteristics of ICIs, we first evaluate the system performance based on the resilience analysis framework proposed in Ref. [27]. The failure-recovery model of system elements and system parameters affecting system resilience are then defined. We propose a set of resilience indicators, including: (1) resilience by mitigation R_m , which corresponds to the capacity of resistance of the system after the disruptions; this depends on the protective measures implemented, (2) resilience by recovery R_r , which refers to the capacity of recovery and it is due to the timeliness and rapidity of

restoration actions, and (3) total resilience R_t , which evaluates the overall resilient performance of a system with the preference of decision makers on mitigation and recovery aspects. A global sensitivity analysis-based importance measure approach is chosen to identify the most critical system parameters with respect to system resilience and to suggest the system resilience strategies in different phases of a disruptive event. Finally, this approach is illustrated by a case study, which consists of two interdependent CIs: a gas network and an electric power system. We compare the improvements of system resilience under the guidelines gained from the proposed approach and from a classical approach. The advantages and limitations of the proposed resilience metric are discussed.

The rest of the paper is organized as follows: Sec. 2 introduces the ICI modeling framework, discusses the failure-recovery mechanisms on ICI, and defines related system parameters. In Sec. 3, the generic resilience indicators are proposed and represented in terms of the system dynamic performance function. The operative steps of the distribution-based global sensitivity analysis are also introduced. Section 4 applies the proposed resilience assessment and importance measures on a case study. The results obtained from the proposed approach and from a classical approach are compared. Section 5 concludes the work and future perspective.

2 Optimization-Based Modeling Framework

In this section, we introduce a modeling framework for ICIs, which is able to address the diversity of flows within different types of CIs and handle the constraints on system states. In the modeling framework, the system behavior in the nominal operation mode and the failure mode is supposed to be under control and described by a set of dynamic equations. The flow distribution on ICIs is formulated and solved by model predictive control (MPC) algorithm. Then we discuss the failure-recovery mechanism of system elements and introduce the system parameters affecting system resilience.

2.1 Network Representation of Interdependent Critical Infrastructures

The functionality of ICIs relies on the exchanges of the different types of resources, which is tangible commodities or intangible services within it. Taking advantage of network theory, we represent the structure of the ICIs by a directed graph, as shown in Fig. 1. The nodes in the graph represent the subsystems in ICIs, which are components or groups of components [28]. Various flows within ICIs are produced, consumed, stored, and transformed by the subsystems. The links in the network are tangible connections, i.e., gas pipelines, or intangible connections, i.e., logical dependency, between the nodes.

Figure 1 shows a classical structure of ICIs. The subsystems within ICIs are classified into five common roles, i.e., suppliers,




Fig. 1 A classical structure of ICIs

users, transporters, converters, and buffers. Suppliers are the sources of resource or service, e.g., renewable energy generators, water treatment plants, natural gas processing facilities. Users are the sinks in the networks, which consume the resources and absorb the flow, e.g., end users of electricity, gas, and water. Transporters are the subsystems distributing the flows received from the precedent subsystems, e.g., substations of the power grid and compressor stations of a gas transmission network. Converters are the subsystems transforming one type of resource or service to another, e.g., fossil-fuel power station. Buffers are the subsystems with storage, e.g., batteries in power grids and gas reservoirs in the gas transmission network.

2.2 Control-Based Dynamic Model. Depending on the roles of each node, we consider input flow, output flow, and/or storage level for them and the links associated with them. The output flow of the links downstream buffer nodes and the system driver nodes [29] are designated as system control inputs to guarantee system controllability. The following state-space model is used to model the evolution of system response under control:

$$\begin{aligned} x(t+1) &= Ax(t) + Bu(t) + d(t) \\ y(t) &= Cx(t) \end{aligned} \quad (1)$$

where $x = [x_1 \dots x_{N_x}]' \in R^{N_x}$ is the vector of the system states, which include the storage levels of buffer nodes, and output flow levels of links. $u = [u_1 \dots u_{N_u}]' \in R^{N_u}$ is the vector of the control variables. $y = [y_1 \dots y_{N_y}]' \in R^{N_y}$ is the vector of the system outputs, which is the actual level of the flows received by users. $d = [d_1 \dots d_{N_d}]' \in R^{N_d}$ is the vector of disturbance variables associated with the losses of the system states due to the disruptions. The $N_x \times N_x$ matrix A and the $N_u \times N_x$ ($N_u \leq N_x$) matrix B contain the information of the system's connectivity and the transmission coefficients of flows.

The values of system states and control variables are typically limited by the capacities of the nodes and the links. The constraints are formulated as follows:

$$0 \leq x(t) \leq CP_x \quad (2)$$

$$0 \leq u(t) \leq CP_u \quad (3)$$

where the elements in CP_x and CP_u take values of the capacities of corresponding nodes or links. More details will be introduced in the next subsection.

The readers requiring more information about ICIs modeling framework please refer to Ref. [27].

2.3 Failure-Recovery Mechanism and System Parameters.

To describe the response of a system in the failure scenarios, we conclude a typical microscopic process of failure and recovery, i.e., failure-recovery mechanism of a system element (a node or a link), and define some system parameters in both time and system elements capacities dimensions in the aftermath of disruption. Figure 2 shows the failure-recovery curve of a failed element i .

In nominal operation mode, the capacity of an element, which is the maximum of its states, remains as a fixed value. We denote CP_i^N as the nominal capacity of i .

At time t_f , the stress of an initiating disruptive event hits element i and results in the failure of element i of the ICIs, i.e., a subsystem or a link. As a consequence of the element failure, its nominal capacity, e.g., CP_i^N , turns to a degradation state with reduction level F_i . Note that F_i could be as large as CP_i^N , i.e., element i is failed completely. The failure process at component level is usually very short compared to the time required for its restoration, and therefore it is regarded as instantaneous in Fig. 2. Then, we define response time H_r to reflect the rapidity of the failure detection and preparedness of emergency actions of the system [30]. After the response time, i.e., at time instant $t_r = t_f + H_r$,




Fig. 2 The evolution of the capacity of a failed component in ICIs

element i starts to be recovered. In some system models, the component state is a binary, i.e., it is in either function mode or failure mode, a failed component is supposed to be able to restore immediately after the execution of recovery activities. Owing to the continuous component state in our model, we are able to consider a more complex failure and recovery process for the elements in ICIs. For example, the recovery process of a failed element i follows a linear function with a maintenance rate μ_i , which relies on the effectiveness of recovery activities. Therefore, the capacity of element i during the disruptive event, CP_i , can be represented as

$$CP_i(t) = CP_i^N - F_i + \mu_i(t - t_r) \quad (4)$$

where

$$F_i = \begin{cases} 0 & \text{for } 0 \leq t < t_f \\ \text{magnitude of failure} & \text{for } t \geq t_f \end{cases} \quad (5)$$

$$\mu_i = \begin{cases} 0 & \text{for } 0 \leq t < t_r \\ \text{recovery rate} & \text{for } t \geq t_r \end{cases} \quad (6)$$

The capacities of system elements are expected to reach their original levels after the restoration activities, i.e., $CP_i(t) \leq CP_i^N$. In fact, depending on the applications, we can consider more complex recovery functions to describe the component recovery process under the current modeling framework. In fact, the performance restoration speed of some complex components varies with time, for example, the recovery speed of components in freight system goes slower as slower, as the easy part will be recovered at first and the hard part will be recovered later [31]. Depending on the application and complexity of modeling, non-linear functions can also be taken into account and accommodate to our modeling framework. For the sake of simplicity, we use a linear form for the recovery function of failed devices in the following of this work.

Once the restoration actions are implemented in the failed elements, i.e., from the instant t_r , the system performance will gradually increase. We define the time interval H_h as the maximum time interval considered acceptable to restore the entire system, i.e., the system is expected to return to the nominal state before the instant $t_h = t_f + H_h$.

In the case of disruption, the disturbances result in malfunction or damage of some elements. Due to the physical connections and functional dependencies among the elements, there are two possible types of propagated failures that occurred in ICIs: (1) the incapability or incapable failure that is caused by the structural or functional damages of elements, due to external disturbance or dependency on others. In this case, the capacity of the element reduces and (2) the inoperability, or inoperable failure, that results from the stop of upstreaming flow supply. In this case, the capacity of the element remains in a nominal level.

Hereafter, we focus on incapable failure cases, as the restoration activities are implemented on the incapable elements, and not on the inoperable elements. For the latter, they continue functioning immediately after the restoration of the elements that they depend on.

2.4 Solution by Model Predictive Control Algorithm. Taking into account the evolution in resource supplies due to renewable energy technologies and variances in user demands, different control strategies can be applied to distribute the resources. We embrace the MPC algorithm, which has been widely applied in CIs, such as in traffic control, resources dispatching, and energy scheduling problems [32]. The classical MPC approach realizes a finite horizon optimization by determining sequences of system states and control operations over a prediction horizon N_q for the minimization of the objective function at each time-step within N_q , and, then, implementing only the first control action [33]. If N_q is large enough, the varying demands of users can be fulfilled, as the allocation of resources is regulated in advance. Notice that many variants exist in the literature besides the classical MPC scheme. For instance, nonlinear MPC can be used for multivariable nonlinear systems with large delays and strong perturbations, although at the expense of computational complexity [34]; explicit MPC is able to compute the optimal control action offline by exploiting the parametric programming technique and is suited to control systems with fast dynamics requiring fewer run-time computations [35]; robust variants of MPC [36] seek to design controllers that maintain stability and performance despite model inaccuracies or uncertainties, e.g., by adopting the min-max MPC formulation. Interested readers can refer to Ref. [37] for a comprehensive discussion and review on the developments of MPC. In this study, we use the classical MPC method for the sake of conceptual simplicity and computational efficiency.

Considering that the units of the resources in ICIs are different, we represent the level of relative insufficiency of user i_y , by a normalized and nondimensional variable

$$Y_{i_y}(t) = \frac{D_{i_y}(t) - y_{i_y}(t)}{D_{i_y}(t)} \quad (7)$$

Based on our dynamic model, the objective function is formulated to minimize the weighted sum of insufficiency function $Y_{i_y}(t)$ of users $i_y \in V_u$, within a predictive horizon N_q

$$\min \sum_{q=0}^{N_q} \left(\sum_{i_y \in V_y} \omega_{i_y} Y_{i_y}(t+q|t) \right) \quad (8)$$

where ω_{i_y} is the weight assigned to the user i_y , and $\sum_{i_y \in V_y} \omega_{i_y} = 1$. The objective function is subject to the constraints in Sec. 2.2.

By solving the optimization problem with MPC, the control action $u(t|t)$ is obtained from the control sequence

$$u \triangleq \{u(t|t), u(t+1|t), \dots, u(t+N_q-1|t)\} \quad (9)$$

as a result of the optimization problem. Then, only the first control action $u(t|t)$ will be introduced in the recursion to calculate the system states at $t+1$.

3 Resilience Metric and Importance Measure

3.1 Generic Resilience Metric With Three Indicators. As introduced before, there are various metrics proposed in the literature for the quantification of infrastructure system resilience. The main differences in the various resilience definitions and metrics stand in the way the capability to face adverse events is considered and measured, e.g., with respect to the time needed to recover system functionalities, to the down time during which urban

services are not provided, to the number of citizens reallocated, to the urban efficiency loss, and so forth [18–20,24]. Nevertheless, all represent aspects directly related to system functionality and to the ability to guarantee continuity of service, even when the global situation is compromised.

The system performance curve in relation to the system resilience property is typically triangular [15,38,39] or trapezoid [12,16,40], the former being representative of a system failure process which is almost instantaneous (e.g., following an earthquake) and the latter explicitly representing the process of gradual system performance degradation. Here we adopt the latter representation for ICIs as shown in Fig. 3, where the y-axis represents the performance function of a system, $P(t)$ and its level in nominal conditions is represented by a reference function $PR(t)$ (usually regarded as constant). Notice that Fig. 3 is different from the component level capacity degradation illustrated in Fig. 2.

A representative method to evaluate system resilience based on the system performance curve is performance-integration resilience metrics [18,41,42]. The essence of this method is to evaluate the difference between the two system performance curves, i.e., expected system performance and actual system performance, or the system performance with original resilience strategies and with improved resilience strategies, over the time horizon of a disruptive event. This method is suitable for various applications and able to include the statistical properties of the randomness on the disruptions and system parameters [14].

In this work, we follow the line of Ref. [8] and extend the basic performance-integration resilience metric to a set of resilience indicators for ICIs including: (1) resilience by mitigation R_m , which corresponds to the capacity of resistance of the system after the disruptions and depends on the protective activities implemented and (2) resilience by recovery R_r , which refers to the capacity of recovery and it is due to the restoration strategies.

The resilience by mitigation is quantified as the proportion of the total area between actual system performance function $P(t)$ and the time axis (the area shaded with upward diagonal stripes in Fig. 3), to the total area between performance reference function $PR(t)$ and the time axis, for the time period $t_f \leq t \leq t_r$, which corresponds to the response time $H_r = t_r - t_f$, i.e., within the mitigation phase

$$R_m = \frac{\int_{t_f}^{t_r} P(t) dt}{\int_{t_f}^{t_r} PR(t) dt} \quad (10)$$

Similarly, the resilience by recovery is the proportion of the total area between actual system performance function $P(t)$ and the time axis (the area shaded with downward diagonal stripes in Fig. 3) to the area between performance reference function $PR(t)$




Fig. 3 System performance curves following the occurrence of an adverse event

and the time axis, for the time period $t_r \leq t \leq t_h$ with $t_h \geq t_r$, i.e., from the start of restoration to the end of time horizon, $H_h - H_r = t_h - t_r$, i.e., within the recovery phase

$$R_r = \frac{\int_{t_r}^{t_h} P(t) dt}{\int_{t_r}^{t_h} PR(t) dt} \quad (11)$$

Besides the two resilience indicators above, the overall level of system resilience, i.e., the total resilience R_t , is illustrated as the combination of two aspects, i.e., the weighted sum of resilience by mitigation and resilience by recovery

$$R_t = \omega_m R_m + \omega_r R_r \quad (12)$$

with both ω_r and ω_m non-negative and $\omega_m + \omega_r = 1$. The definition of the weights depends on the preference of decision makers [43].

In this work, we consider the proportion of the time period of two phases, as the weights

$$\omega_m = \frac{H_r}{H_h} = \frac{t_r - t_f}{t_h - t_f} \quad (13)$$

$$\omega_r = \frac{H_h - H_r}{H_h} = \frac{t_h - t_r}{t_h - t_f} \quad (14)$$

Therefore, the total resilience R_t is represented as

$$R_t = \frac{t_r - t_f}{t_h - t_f} \frac{\int_{t_f}^{t_r} P(t) dt}{\int_{t_f}^{t_r} PR(t) dt} + \frac{t_h - t_r}{t_h - t_f} \frac{\int_{t_r}^{t_h} P(t) dt}{\int_{t_r}^{t_h} PR(t) dt} \quad (15)$$

In some cases where the preference system performance is fixed or approximately fixed over time, i.e., $PR(t) = PR$, the function of R_t are simplified as

$$R_t = \frac{\int_{t_f}^{t_h} P(t) dt}{\int_{t_f}^{t_h} PR(t) dt} = \frac{\int_{t_f}^{t_h} P(t) dt}{PR(t_h - t_f)} \quad (16)$$

which is the proportion of the total area between the actual system performance function $P(t)$ and the time axis (the dark area in Fig. 3), to the square area between the performance reference function $PR(t)$ and the time axis, for the time period $t_f \leq t \leq t_h$ with $t_h \geq t_f$, as shown in Fig. 3.

By the previous definitions, the indicators of resilience-by-mitigation, resilience-by-recovery and the total resilience all take value in the interval $[0, 1]$. When the system remains fully operable under the disruptive event, $R_m = R_r = R_t = 1$. The cases of $R_m = 0$, $R_r = 0$, or $R_t = 0$ indicate extreme situations where the mitigation activities, restoration activities, or both of them lack or fail completely and the functionalities of ICIs are entirely interrupted from the moment where the initial failure occurs to the end of the time horizon.

3.2 Resilience Metric Within Interdependent Critical Infrastructures Dynamic Modeling Framework. Note that in the generic resilience metric, the performance function $P(t)$ of a system can be any quantity of interest. For ICIs, the system performance can be defined from different viewpoints (reliability, availability, safety, economics, etc.), e.g., counting the number of operating components [38], the economic loss associated with the components, and the casualties of people during the disaster [16].

The ICIs aim at providing stable and reliable services to users, and the measure of infrastructure resilience is how they enable and enhance daily life [11]. Given these goals of ICIs, we evaluate time-dependent system performance for ICIs in terms of the relative satisfactory level of users.

Based on the system dynamic model previously introduced, the actual performance function of ICIs, $P(t)$, is characterized directly in terms of the weighted sum of the complement of insufficiency function Y_{i_y}

$$P(t) = \sum_{i_y=1}^{N_y} \omega_{i_y} (1 - Y_{i_y}(t)) = \sum_{i_y=1}^{N_y} \omega_{i_y} \frac{y_{i_y}(t)}{D_{i_y}} \quad (17)$$

where ω_{i_y} with $i_y = 1, \dots, N_y$ is the weight of the i_y th user.

The nominal system performance of ICIs, $PR(t)$, is the normalized performance reference function under nominal operating conditions, which is the normalized total demand of resources or service by the users; therefore, it is fixed value 1

$$PR(t) = \sum_{i_y=1}^{N_y} \omega_{i_y} \frac{D_{i_y}}{D_{i_y}} = 1 \quad (18)$$

The resilience metric for ICIs is obtained

$$R_m = \frac{\int_{t_f}^{t_r} \sum_{i_y=1}^{N_y} \omega_{i_y} \frac{y_{i_y}(t)}{D_{i_y}} dt}{t_r - t_f} \quad (19)$$

$$R_r = \frac{\int_{t_r}^{t_h} \sum_{i_y=1}^{N_y} \omega_{i_y} \frac{y_{i_y}(t)}{D_{i_y}} dt}{t_h - t_r} \quad (20)$$

$$R_t = \frac{\int_{t_f}^{t_h} \sum_{i_y=1}^{N_y} \omega_{i_y} \frac{y_{i_y}(t)}{D_{i_y}} dt}{t_h - t_f} \quad (21)$$

3.3 Global Sensitivity Analysis-Based Importance Measure. To identify the priorities of the protection and recovery strategies, we evaluate the impacts of the system parameters, i.e., failure magnitude and recovery rate of vulnerable elements by a distribution-based global sensitivity analysis (SA) method [44] that allows us to identify the most important factors affecting system resilience. Global sensitivity analysis approaches are used to analyze how the uncertainty in the output of a model can be apportioned to different sources of uncertainty in the inputs of the model [45]. Within the proposed ICIs modeling framework, the uncertainty of system parameters is the scope of the effects of the resilience activities implemented on failed elements. This approach can be used to identify the most important resilience protection and recovery activities affecting the system resilience at different stages during a disruptive event. We choose this global sensitivity analysis approach because compared to traditional variance-based indicators and other moment independent sensitivity indicators, this approach is able to address the issues such as the presence of input variable correlations and loss of information in the distribution, and therefore to respond to more complex situations, e.g., negative correlation between two repair actions due to a defined limited budget. We refer to Ref. [44] for a discussion of the advantages of this method.

The operative steps to perform such SA are given in the following: The core of the distribution-based global sensitivity analysis method is to consider the whole probability distribution of factors and to evaluate their impacts on the system outputs (e.g., the

system resilience, in this paper) by an indicator with respect to the entire output distribution.

For a system model

$$Y = m(X), m(X) : E \subseteq \mathbb{R}^n \rightarrow \mathbb{R} \quad (22)$$

where Y is the output of the model, e.g., the resilience value in our case, and $X = (X_1, X_2, \dots, X_n) \in \mathbb{R}^n$ is the set of uncertain input variables, e.g., the failure magnitude and the recovery rate of vulnerable elements.

The importance measure (IM) for factor X_i is

$$\delta_i = \frac{1}{2} E_{X_i}[s(X_i)] \quad (23)$$

where

$$s(X_i) = \int |f_Y(y) - f_{Y|X_i}(y)| dy \quad (24)$$

which is the shift between the unconditional density distribution $f_Y(y)$ and the conditional density distribution $f_{Y|X_i}(y)$ on fixed value of X_i .

The following algorithm is carried out to obtain the IM for the factor X_i :

Step 1. Define the ranges and probability distributions for $X_i, f_i(x_i)$ with $i = 1, \dots, n$.

Step 2. Compute numerically the unconditional density distribution $f_Y(y)$ by setting all variables as random.

Step 3. Take a realization of $X_i: x_i = \{x_i^1, \dots, x_i^j, \dots, x_i^{n_i}\}, j = 1, \dots, n_i$, and $P(X_i = x_i^j)$ can be obtained from $f_i(x_i)$.

Step 4. Compute the conditional probability distribution of X_i :

(4.1) For each value in the realization of X_i , i.e., x_i^j with $j = 1, \dots, n_i$, sample n_r sets of random values of all other parameters $X_{i'}$ with $i' \neq i: x_{i'}^k = 1, \dots, n_r$;

(4.2) Compute the n_r outputs of system, i.e., y^{jk} with $k = 1, \dots, n_r$, then obtain its distribution $f_{Y|X_i=x_i^j}(y)$;

(4.3) Then, compute the value of $s(x_i^j) = \int |f_Y(y) - f_{Y|X_i=x_i^j}(y)| dy$, for $X_i = x_i^j$.

Step 5. Calculate the value of indicator for the factor X_i :

$$\delta_i = \frac{1}{2} E_{X_i}[s(X_i)] = \frac{1}{2} \left[\sum_{j=1}^{n_i} P(X_i = x_i^j) s(x_i^j) \right].$$

The SA indicator can be used to rank the variables of the model. The higher the value of its SA indicator is, the higher the contribution of this variable to system output. With this method, system parameters in the ICIs model, which are associated with system protection or recovery activities, are sorted. The key resilience strategies and the most important elements are then identified in different phases of the disruptive event.

4 Case Study and Results

4.1 Interconnected Natural Gas Distribution Network and Power Grid. We consider a case study adapted from Ref. [46] consisting of two interconnected CIs: a natural gas distribution network and a power grid (Fig. 4, solid and dash-dotted lines, respectively). The objective of this system is to provide the necessary amount of gas and electricity to the demand nodes. In particular, the gas distribution network supplies gas to two users, D_1 and D_2 , and to two electric power generators, E_1 and E_2 , that provide electricity to two users of electricity, L_1 and L_2 .

The natural gas distribution network has two suppliers, S_1 and S_2 , whose outputs are assumed to be equal to 90 thousand cubic feet (MCF) and 180 MCF, respectively; two buffers (gas




Fig. 4 Interconnected natural gas-power systems. S: supplier, DS: buffer/gas reservoir, D: gas users. E: electrical power generator, G: electrical transporters, and L: electricity users. The vulnerable elements (nodes and links) are marked in red and bold.

reservoirs), DS_1 and DS_2 ; five transporters a, b, c, d , and e ; and two users D_1 and D_2 , whose demands, D_{D1} and D_{D2} , are equal to 100 MCF and 80 MCF, respectively. The electric power network has two converters (electric power generators), E_1 and E_2 , that transform gas into electricity with a constant coefficient β , where $\beta=10$ megawatt-hours (MWh) per MCF, i.e., 1 MCF of natural gas produces 10 MWh of electricity; two transporters, G_1 and G_2 ; and two users L_1 and L_2 , whose demands, D_{L1} and D_{L2} , are equal to 500 MWh and 400 MWh, respectively.

Based on the data provided in Ref. [46], the vulnerable elements, i.e., the nodes and links, are marked in bold and in red as shown in Fig. 4. In the failure scenarios of the following simulation, the response time and the time horizon of a disruptive event are $H_r = 15$ (hours) and $H_h = 85$ (hours). The failure magnitudes and recovery rates of these elements are considered as uncertain variables following uniform distributions to reflect the flexibility of the decision on system resilience strategies. The magnitude of the failure of vulnerable element i, F_i , is limited by its capacity, i.e., $F_i = [F_{i\min}, F_{i\max}] = [0, C_i]$, where C_i is the capacity of i , in units of MCF and MWh for the gas system and power grid, respectively. The recovery rate of a failed element μ_i can vary within $[\mu_{i\min}, \mu_{i\max}]$ where $\mu_{i\min} = \frac{F_{i\min}}{(H_i - H_r)}$ and $\mu_{i\max} = \frac{F_{i\max}}{(H_i - H_r)}$, with the units MCF/hours and MWh/hours for the gas system and the power grid, respectively. The detailed ranges of system parameters, i.e., failure magnitudes and recovery rates of these vulnerable elements, are shown in Table 1.

4.2 Importance Measure in Different Phases of a Disruptive Event.

The evolution of system performance under the disruptive event can be evaluated within the ICIs modeling framework. The system resilience in different failure scenarios is then assessed with three resilience indicators proposed in Sec. 3. Subsequently, we adopt the IMs to identify the critical system elements in the mitigation and recovery phases and compare their effectiveness. The first two IM approaches are both driven by the global sensitivity analysis introduced in Sec. 3. The difference

Table 1 Ranges of uncertain system parameters

Element i	Failure magnitude F_i	Recovery rate μ_i
Supplier S_1	[0, 90] MCF	[0, 1.8] MCF/hrs
Supplier S_2	[0, 180] MCF	[0, 3.6] MCF/hrs
Link L_{a-b}	[0, 300] MCF	[0, 6] MCF/hrs
Link L_{b-c}	[0, 170] MCF	[0, 3.4] MCF/hrs
Link L_{c-d}	[0, 100] MCF	[0, 2] MCF/hrs
Link L_{d-e}	[0, 100] MCF	[0, 2] MCF/hrs
Link $L_{E_1-G_1}$	[0, 800] MWh	[0, 16] MWh/hrs
Link $L_{E_2-G_2}$	[0, 400] MWh	[0, 8] MWh/hrs

between them is that in the first approach, we use the indicators resilience by mitigation and resilience by recovery, and the IM taken in the recovery phase is based on the results obtained in the mitigation phase. In the second approach, total resilience is the only indicator to consider.

To test the effectiveness of the IM approaches, we design a resilience improvement scheme. A unitary increment $dv \in [0, 10]$ for system parameters is considered to indicate the effects of resilience reinforcement strategies. The increment values of the system parameters rely on the priority of vulnerable elements. Based on the original level of a system parameter, e.g., the average, the parameter increases or reduces $5dv$ percent if it ranks first, $4dv$ percent if it ranks second, $3dv$ percent if it ranks third, $2dv$ percent if it ranks fifth, and dv percent for the rest cases. Coordinating with the results from different IM approaches, this scheme is adopted in both the mitigation and recovery phases to improve the system resilience.

4.2.1 Importance Measure by SA With Resilience by Mitigation and Resilience by Recovery. This IM approach is based on the proposed resilience metrics. With separate indicators in the mitigation and recovery phases, the global SA is performed sequentially on the mitigation phase and the restoration phase so that the contributions of mitigation activities and recovery activities are differentiated. We consider the failure scenarios where all vulnerable elements are disturbed by a disruptive event.

In the mitigation phase, we evaluate the sensitivity of the resilience by mitigation, i.e., R_m on the failure magnitude of vulnerable elements. The recovery rates of elements are fixed to the average levels. The SA indicator values of the failure magnitudes of the system elements are shown in Table 2. The elements with high values of importance indicators have high priority in the mitigation phase.

The IM taken in the recovery phase is based on the results obtained in the mitigation phase. According to the results obtained from SA of resilience by mitigation, we improve all failure magnitudes with $dv=10$. Then, we evaluate the sensitivity of the resilience by recovery, i.e., R_r on the recovery rates of vulnerable elements with the update failure magnitudes. The SA indicator values in the recovery phase are shown in Table 3.

4.2.2 Importance Measure by SA With Total Resilience. In this approach, we also consider the failure scenarios where all vulnerable elements are disturbed by a disruptive event. Supposing that only the total resilience R_t is available, the global SA is adopted to evaluate the sensitivity of R_t on all system parameters. The results of this IM method support the ranking of all system parameters (column 3, Table 4). To implement the resilience improvement scheme in both the mitigation and recovery phases, we rank the failure magnitude and the recovery rate, respectively, according to the values of SA indicators. The priority order of system elements in the mitigation phase and recovery phase are then obtained (column 4, Table 4).

4.2.3 Importance Measure by a Classical Method. Then, we apply a traditional method to identify the most vulnerable elements in ICIs. Different from the previous two methods, this

Table 3 Importance measures of parameters in the recovery phase

Element i	Parameter F_i	IM $\delta_{F_i}^{R_r}$	Rank
S_1	μ_{S_1}	0.0063	2
S_2	μ_{S_2}	0.0238	1
L_{a-b}	$\mu_{L_{a-b}}$	0.0020	7
L_{b-c}	$\mu_{L_{b-c}}$	0.0050	3
L_{c-d}	$\mu_{L_{c-d}}$	0.0043	4
L_{d-e}	$\mu_{L_{d-e}}$	0.0033	6
$L_{E_1-G_1}$	$\mu_{L_{E_1-G_1}}$	0.0040	5
$L_{E_2-G_2}$	$\mu_{L_{E_2-G_2}}$	0.0015	8

Table 4 Importance indicators of parameters in the mitigation phase

Parameters	IM $\delta_{F_i}^{R_t}$	Rank	Rank in M/R phases
F_{S_1}	0.0047	6	5
F_{S_2}	0.0090	2	2
$F_{L_{a-b}}$	0.0132	1	1
$F_{L_{b-c}}$	0.0050	5	4
$F_{L_{c-d}}$	0.0027	12	7
$F_{L_{d-e}}$	0.0027	11	6
$F_{L_{E_1-G_1}}$	0.0082	3	3
$F_{L_{E_2-G_2}}$	0.0025	15	8
μ_{S_1}	0.0035	9	4
μ_{S_2}	0.0045	7	2
$\mu_{L_{a-b}}$	0.0053	4	1
$\mu_{L_{b-c}}$	0.0037	8	3
$\mu_{L_{c-d}}$	0.0027	13	6
$\mu_{L_{d-e}}$	0.0026	14	7
$\mu_{L_{E_1-G_1}}$	0.0033	10	5
$\mu_{L_{E_2-G_2}}$	0.0025	16	8

method combines failure occurrence probability and consequence severity of the failure on vulnerable elements to evaluate their criticality. The system performance for each failure scenario is obtained through the simulation, assuming that as a certain vulnerable element i is affected by disruptions, but under the worst condition: $F_i = F_{i\max}$ and $\mu_i = \mu_{i\min}$.

The probability of initial failure occurred on i , PE_i , is computed based on the transition matrices in the semi-Markov processes [46]. The sum of the steady-state probabilities of failure modes of each vulnerable element is denoted as its failure probability, PE_i (column 2, Table 5). The third column in Table 5 shows the values of the total resilience R_{ti} in each failure scenario.

Then, we convert the failure occurrence probability and consequence severity of each vulnerable element i into two criteria. The failure occurrence probability, PE_i is used to calculate the indicator of occurrence, I_i^o , through $I_i^o = -\log_{10} PE_i$, and then the score of likelihood O_i of the element i is obtained in Table 6. The total system resilience R_{ti} is transformed into the indicator of the severity of scenario i , I_i^s , with $I_i^s = 1 - R_{ti}$, and then the score of likelihood S_i can be calculated as shown in Table 7.

Table 2 Importance indicators of parameters in the mitigation phase

Element i	Parameter F_i	IM $\delta_{F_i}^{R_m}$	Rank
S_1	F_{S_1}	0.0021	8
S_2	F_{S_2}	0.0060	3
L_{a-b}	$F_{L_{a-b}}$	0.0217	1
L_{b-c}	$F_{L_{b-c}}$	0.055	4
L_{c-d}	$F_{L_{c-d}}$	0.0031	6
L_{d-e}	$F_{L_{d-e}}$	0.0042	5
$L_{E_1-G_1}$	$F_{L_{E_1-G_1}}$	0.0120	2
$L_{E_2-G_2}$	$F_{L_{E_2-G_2}}$	0.0026	7

Table 5 Failure scenario resilience indicators

Element i	PE_i	R_{ti}
Supplier S_1	0.3000	0.7522
Supplier S_2	0.0033	0.3819
Link L_{a-b}	0.0847	0.1077
Link L_{b-c}	0.0847	0.3294
Link L_{c-d}	0.0847	0.7113
Link L_{d-e}	0.0847	0.7016
Link $L_{E_1-G_1}$	0.0011	0.5796
Link $L_{E_2-G_2}$	0.0013	0.9372

Table 6 Failure occurrence criteria

Likelihood	Occurrence indicator I_i^o	Score of likelihood O_i
Probable	[0, 1)	10
	[1, 2)	9
	[2, 3)	8
	[3, 4)	7
	[4, 5)	6
Remote	[5, 6)	5
	[6, 7)	4
Extremely remote	[7, 8)	3
	[8, 9)	2
Extremely improbable	[9, +∞)	1

Table 7 Severity evaluation criteria

Severity description	Severity indicator I_i^S	Score of severity S_i
Catastrophic	[0.9, 1)	10
	[0.8, 0.9)	9
Hazardous	[0.7, 0.8)	8
	[0.6, 0.7)	7
Major	[0.5, 0.6)	6
	[0.4, 0.5)	5
Minor	[0.3, 0.4)	4
	[0.2, 0.3)	3
No effect	[0.1, 0.2)	2
	[0, 0.1)	1
	0	0

Table 8 Failure scenario resilience indicators

Element i	$Q_i^{R_i}$	Rank
Supplier S_1	21	5
Supplier S_2	48	3
Link L_{a-b}	81	1
Link L_{b-c}	54	2
Link L_{c-d}	18	6
Link L_{d-e}	18	6
Link $L_{E_1-G_1}$	32	4
Link $L_{E_2-G_2}$	8	7

Based on the scores of failure likelihood and the scores of consequence severity for the vulnerable elements, we calculate their priority indicators, $Q_i^{R_i} = S_i \cdot O_i$. The results are shown in Table 8. With this classical method, the rank of vulnerable elements is obtained. The four most important elements are link L_{a-b} , link L_{b-c} , supplier S_2 and link $L_{E_1-G_1}$, and this order will be considered in the resilience improvement scheme in both mitigation and recovery phases.

4.3 Comparison of Results. We have obtained the ranks of vulnerable system elements by three IM approaches: (1) global SA-based IM considering mitigation and recovery aspects

Table 9 The rank of system parameters in the mitigation phase

Rank	Method 1	Method 2	Method 3
1	L_{a-b}	L_{a-b}	L_{a-b}
2	$L_{E_1-G_1}$	$L_{E_1-G_1}$	L_{b-c}
3	S_2	S_2	S_2
4	L_{b-c}	L_{b-c}	$L_{E_1-G_1}$
5	L_{d-e}	S_1	S_1
6	L_{c-d}	L_{d-e}	$L_{c-d} L_{d-e}$
7	$L_{E_2-G_2}$	L_{c-d}	$L_{E_2-G_2}$
8	S_1	$L_{E_2-G_2}$	

Table 10 The rank of system parameters in the recovery phase

Rank	Method 1	Method 2	Method 3
1	S_2	L_{a-b}	L_{a-b}
2	L_{b-c}	S_2	L_{b-c}
3	L_{c-d}	L_{b-c}	S_2
4	S_1	$L_{E_1-G_1}$	$L_{E_1-G_1}$
5	$L_{E_1-G_1}$	S_1	S_1
6	L_{d-e}	L_{c-d}	$L_{c-d} L_{d-e}$
7	L_{a-b}	L_{d-e}	$L_{E_2-G_2}$
8	$L_{E_2-G_2}$	$L_{E_2-G_2}$	




Fig. 5 Improvement of system resilience with different levels of increment dv

separately, (2) global SA-based IM with total resilience indicator, and (3) a classical method. We are interested in comparing the effects of their ranking results.

The ranking order indicating the criticality of the vulnerable elements in the mitigation phase and the recovery phase is shown in Tables 9 and 10, respectively. The results provided by method 1 show that the priority of system elements in the recovery phase is different from that in the mitigation phase. In the mitigation phase, the rank order obtained from method 1 is quite similar to method 2. All three approaches confirm the criticality of the link L_{a-b} . In the recovery phase, their results from the three methods are dissimilar.

To test the effects of three sorting methods, we consider improving the system resilience according to the sorting results from the three IM methods, under the same original failure scenario, i.e., failure magnitudes and recovery rates of the elements are equal to their average levels. The resilience improvement schema is applied: failure magnitudes and recovery rates of the elements are reduced or increased according to the ranking results in the mitigation phase and recovery phase, respectively.

Figure 5 shows the evolution of the curve of system resilience, R_i , with the increasing increment of system parameters, dv . Notice that the y-axis representing R_i is in the range of [0, 1] by its definition given in Eq. (21). When the increment is small, the classical method produces a better effect. But with the increase of increment, the first IM method, i.e., the method based on the proposed resilience indicators, shows its effectiveness.

More precisely, we take a look at the case where $dv=10$ to compare system performance of ICIs after different resilience improvement strategies are taken. As shown in Fig. 6, the lowest value of system performance with method 1 and method 2 is the same, as they have similar ranking results in the mitigation phase. With method 3, the failure propagation process is longer and the lowest value reached by the system performance curve is lower than others. In the recovery phase, the improved system performance with method 1 is the first to recover back to the nominal value.

Compared to the other two approaches, the IM approach with the proposed resilience metric is more effective. That is because




Fig. 6 The evolution of system performance with three methods, $d\nu=10$

the proposed resilience indicators allow us to obtain updated priority of system elements in mitigation and recovery phases.

The limitation of the IM approach with the proposed resilience metric is the relatively high computational cost. To calculate SA indicator of each system parameter in any of the two phases requires 10^6 iterations. Therefore, the computational cost of method 1 is two times of method 2 and is much more expensive than method 3.

5 Conclusion

This paper proposed a generic system resilience metric, which evaluates separately the two aspects of system resilience, i.e., the capacity of resistance gained from protective measures implemented and the capacity of recovery owing to the restoration actions. By taking into account the characteristics of ICIs, we evaluate the system performance in terms of users' satisfaction within a control-based dynamic modeling framework. Then, we apply the proposed resilience metric to measure the criticality of system elements from the perspective of their contribution to system resilience in the mitigation and recovery phases. A global SA approach is used to evaluate the level of dependencies of the system resilience on system parameters associated with the system elements.

Three importance measure (IM) approaches are performed on a case study composing of a natural gas distribution network and a power grid. The first one is a global SA-based IM with resilience by mitigation and resilience by recovery indicators, i.e., the proposed resilience metric. The second one is also global SA-driven, but only considers the total system resilience. The third one is a classical method combining the failure occurrence probability and consequence severity in the worst failure scenario of each vulnerable element. We obtained the ranks of system parameters in different phases of a disruptive event and then conclude the priorities of vulnerable elements, which should be protected and recovered. A system resilience improvement scheme is considered to compare the effectiveness of three IM methods. Compared to the other two approaches, the IM approach with the proposed resilience metric shows higher effectiveness.

Note that since the resilience assessment approaches in literature are not able to quantitatively differentiate the contributions of the mitigation and recovery aspects, they cannot provide decision makers the separate priority of system elements in different phases. Instead, the proposed multiple resilience indicators and the corresponding IM approach provide more insights to decision makers to increase the effectiveness of system resilience improvement strategies. Moreover, the generic resilience metric is also applicable to a variety of domains and many situations, such as system resilience design, system resilience improvement, and system resilience examination.

The proposed IM approach is computationally costly compared to existing methods. Nevertheless, it should be mentioned that this is not necessarily a real concern due to the significant

advancement in computing power. Actually, the proposed approach can be applied to both real-time tactical emergency management and long-term strategic planning, for which computation is often done offline. For long-term strategic planning, historical failure data can be fed into the proposed approach for identifying the statistically most vulnerable and critical elements in ICIs, for protection and upgrading. Also, our approach is able to support predisruption preparedness activities when the most significant characteristics of the emergent hazard, and the associated failure scenarios of the system, can be postulated (e.g., for tropical storms and hurricanes, flooding, blizzards).

In real emergency scenarios, system operation parameters (such as the electricity and gas demand) might be highly variable and uncertain and affect the system performance quantification. This should be taken into account in the robust application of the proposed method. Last but not least, this study has not considered the cost associated with the resilience reinforcement strategies, which requires detailed models of the protection and restoration actions of system components. Such developments will be investigated in future works.

References

- [1] Kröger, W., and Zio, E., 2011, *Vulnerable Systems*, Springer London, London.
- [2] Zio, E., 2016, "Challenges in the Vulnerability and Risk Analysis of Critical Infrastructures," *Reliab. Eng. Syst. Saf.*, **152**, pp. 137–150.
- [3] Zio, E., 2009, "Reliability Engineering: Old Problems and New Challenges," *Reliab. Eng.*, **94**(2), pp. 125–141.
- [4] Buldyrev, S. V., Parshani, R., Paul, G., Stanley, H. E., and Havlin, S., 2010, "Catastrophic Cascade of Failures in Interdependent Networks," *Nature*, **464**(7291), pp. 1025–1028.
- [5] Fang, Y., and Zio, E., 2019, Game-Theoretic Decision Making for the Resilience of Interdependent Infrastructures Exposed to Disruptions, D. Gritzalis, M. Theocharidou, G. Stergiopoulos, eds., *Critical Infrastructure Security and Resilience*, Advanced Sciences and Technologies for Security Applications, Springer, Cham, Switzerland, pp. 97–114.
- [6] Fang, Y.-P., and Zio, E., 2019, "An Adaptive Robust Framework for the Optimization of the Resilience of Interdependent Infrastructures Under Natural Hazards," *Eur. J. Oper. Res.*, **276**, pp. 1119–1136.
- [7] Yu, J.-Z., and Baroud, H., 2020, "Modeling Uncertain and Dynamic Interdependencies of Infrastructure Systems Using Stochastic Block Models," *ASCE-ASME J. Risk Uncert. Eng. Syst. Part B Mech. Eng.*, **6**(2), p. 020906.
- [8] Ayyub, B. M., 2014, "Systems Resilience for Multihazard Environments: Definition, Metrics, and Valuation for Decision Making," *Risk Anal.*, **34**(2), pp. 340–355.
- [9] Salomon, J., Broggi, M., Kruse, S., Weber, S., and Beer, M., 2020, "Resilience Decision-Making for Complex Systems," *ASCE-ASME J. Risk Uncert. Eng. Syst. Part B Mech. Eng.*, **6**(2), p. 020901.
- [10] Ayyub, B. M., Pantelous, A. A., and Shao, J., 2016, "Toward Resilience to Nuclear Accidents: Financing Nuclear Liabilities Via Catastrophe Risk Bonds," *ASCE-ASME J. Risk Uncert. Eng. Syst. Part B Mech. Eng.*, **2**(4), p. 041005.
- [11] Hosseini, S., Barker, K., and Ramirez-Marquez, J. E., 2016, "A Review of Definitions and Measures of System Resilience," *Reliab. Eng. Syst. Saf.*, **145**, pp. 47–61.
- [12] Henry, D., and Ramirez-Marquez, J. E., 2012, "Generic Metrics and Quantitative Approaches for System Resilience as a Function of Time," *Reliab. Eng. Syst. Saf.*, **99**, pp. 114–122.
- [13] Yodo, N., and Wang, P., 2016, "Engineering Resilience Quantification and System Design Implications: A Literature Survey," *ASME J. Mech. Des.*, **138**(11), p. 111408.
- [14] Jin, C., Li, R., Kang, R., 2017, "Analysis and Comparison of Three Measures for System Resilience," *Risk, Reliability and Safety: Innovating Theory and Practice*, Taylor & Francis Group, London, pp. 2145–2151.
- [15] Bruneau, M., Chang, S. E., Eguchi, R. T., Lee, G. C., O'Rourke, T. D., Reinhorn, A. M., Shinozuka, M., Tierney, K., Wallace, W. A., and von Winterfeldt, D., 2003, "A Framework to Quantitatively Assess and Enhance the Seismic Resilience of Communities," *Earthq. Spectra*, **19**(4), pp. 733–752.
- [16] Ouyang, M., Duenas-Osorio, L., and Min, X., 2012, "A Three-Stage Resilience Analysis Framework for Urban Infrastructure Systems," *Struct. Saf.*, **36–37**, pp. 23–31.
- [17] Fang, Y.-P., Pedroni, N., and Zio, E., 2016, "Resilience-Based Component Importance Measures for Critical Infrastructure Network Systems," *IEEE Trans. Reliab.*, **65**(2), pp. 502–512.
- [18] Nan, C., and Sansavini, G., 2017, "A Quantitative Method for Assessing Resilience of Interdependent Infrastructures," *Reliab. Eng. Syst. Saf.*, **157**, pp. 35–53.
- [19] Kong, J., and Simonovic, S. P., 2019, "Probabilistic Multiple Hazard Resilience Model of an Interdependent Infrastructure System," *Risk Anal.*, **39**(8), pp. 1843–1863.
- [20] Francis, R., and Bekera, B., 2014, "A Metric and Frameworks for Resilience Analysis of Engineered and Infrastructure Systems," *Reliab. Eng. Syst. Saf.*, **121**, pp. 90–103.

- [21] Fisher, R. E., Bassett, G. W., Buehring, W. A., Collins, M. J., Dickinson, D. C., Eaton, L. K., Haffenden, R. A., Hussar, N. E., Klett, M. S., Lawlor, M. A., Millier, D. J., Petit, F. D., Peyton, S. M., Wallace, K. E., Whitfield, R. G., and Peerenboom, J. P., 2013, "Constructing a Resilience Index for the Enhanced Critical Infrastructure Protection Program," *Argonne Natl. Lab.*, **53**, pp. 1689–1699.
- [22] Westmark, V. R., 2004, "A Definition for Information System Survivability," Proceeding of 37th Annual Hawaii International Conference Systems Science, Big Island, HI, Jan. 5–8, pp. 1–10.
- [23] Jackson, S., and Ferris, T. L. J., 2013, "Resilience Principles for Engineered Systems," *Syst. Eng.*, **16**(2), pp. 152–164.
- [24] Uday, P., and Marais, K., 2015, "Designing Resilient Systems-of-Systems: A Survey of Metrics, Methods, and Challenges," *Syst. Eng.*, **18**(5), pp. 491–510.
- [25] Zobel, C. W., 2011, "Representing Perceived Tradeoffs in Defining Disaster Resilience," *Decision Support Syst.*, **50**(2), pp. 394–403.
- [26] Rose, A., 2007, "Economic Resilience to Natural and Man-Made Disasters: Multidisciplinary Origins and Contextual Dimensions," *Environ Hazards*, **7**(4), pp. 383–398.
- [27] Liu, X., Ferrario, E., and Zio, E., 2017, "Resilience Analysis Framework for Interconnected Critical Infrastructures," *ASCE-ASME J. Risk Uncert. Eng. Syst., Part B Mech. Eng.*, **3**(2), p. 021001.
- [28] Galbusera, L., Ntalampiras, S., Azzini, I., and Giannopoulos, G., 2013, A Methodology for Resilience Optimisation of Interdependent Critical Infrastructures, *10th International Conference on Critical Information Infrastructures Security*, Springer, pp. 56–66.
- [29] Liu, Y.-Y., Slotine, J.-J., and Barabási, A.-L., 2011, "Controllability of Complex Networks," *Nature*, **473**(7346), pp. 167–173.
- [30] Muller, G., 2012, "Fuzzy Architecture Assessment for Critical Infrastructure Resilience," *Procedia Comput. Sci.*, **12**, pp. 367–372.
- [31] Nair, R., Avetisyan, H., and Miller-Hooks, E., 2010, "Resilience Framework for Ports and Other Intermodal Components," *Transp. Res. Rec. J. Transp. Res. Board*, **2166**(1), pp. 54–65.
- [32] Prodan, I., and Zio, E., 2014, "A Model Predictive Control Framework for Reliable Microgrid Energy Management," *Int. J. Electr. Power Energy Syst.*, **61**, pp. 399–409.
- [33] Camacho, E. F., and Bordons Alba, C., 2013, *Model Predictive Control*, Springer-Verlag London, UK.
- [34] Findeisen, R., and Allgöwer, F., 2002, "An Introduction to Nonlinear Model Predictive Control," 21st Benelux Meeting on Systems and Control, Technische Universiteit Eindhoven Veldhoven Eindhoven, Eindhoven, The Netherlands, Mar. 19–21, pp. 119–141.
- [35] Alessio, A., and Bemporad, A., 2009, "A Survey on Explicit Model Predictive Control," *Nonlinear Model Predictive Control*, Springer, Heidelberg, Germany, pp. 345–369.
- [36] Bemporad, A., and Morari, M., 1999, "Robust Model Predictive Control: A Survey," *Robustness in Identification and Control*, Springer, Berlin, pp. 207–226.
- [37] Mayne, D. Q., 2014, "Model Predictive Control: Recent Developments and Future Promise," *Automatica*, **50**(12), pp. 2967–2986.
- [38] Cimellaro, G. P., Reinhorn, A. M., and Bruneau, M., 2010, "Framework for Analytical Quantification of Disaster Resilience," *Eng. Struct.*, **32**(11), pp. 3639–3649.
- [39] Fang, Y.-P., Pedroni, N., and Zio, E., 2017, "Comparing Network-Centric and Power Flow Models for the Optimal Allocation of Link Capacities in a Cascade-Resilient Power Transmission Network," *IEEE Syst. J.*, **1**(3), pp. 1632–1643.
- [40] Dessavre, D. G., Ramirez-Marquez, J. E., and Barker, K., 2016, "Multidimensional Approach to Complex System Resilience Analysis," *Reliab. Eng. Syst. Saf.*, **149**, pp. 34–43.
- [41] Ganin, A. A., Massaro, E., Gutfraind, A., Steen, N., Keisler, J. M., Kott, A., Mangoubi, R., and Linkov, I., 2016, "Operational Resilience: Concepts, Design and Analysis," *Sci. Rep.*, **6**(1), p. 12.
- [42] Ayyub, B. M., 2015, "Practical Resilience Metrics for Planning, Design, and Decision Making," *ASCE-ASME J. Risk Uncertain. Eng. Syst. Part A Civ. Eng.*, **1**, p. 4015008.
- [43] Cimellaro, G. P., Reinhorn, A. M., and Bruneau, M., 2010, "Seismic Resilience of a Hospital System," *Struct. Infrastruct. Eng.*, **6**(1–2), pp. 127–144.
- [44] Borgonovo, E., 2007, "A New Uncertainty Importance Measure," *Reliab. Eng. Syst. Saf.*, **92**(6), pp. 771–784.
- [45] Saltelli, A., 2004, "Global Sensitivity Analysis: An Introduction," Sens. Anal. Model Output, *Proc. 4th International Conference on Sensitivity Analysis of Model Output (SAMO'04)*, pp. 27–43.
- [46] Nozick, L. K., Turnquist, M. A., Jones, D. A., Davis, J. R., and Lawton, C. R., 2005, "Assessing the Performance of Interdependent Infrastructures and Optimising Investments," *Int. J. Crit. Infrastruct.*, **1**(2/3), pp. 144–154.