© 2021 IEEE. Personal use of this material is permitted. Permission from IEEE must be obtained for all other uses, in any current or future media, including reprinting/republishing this material for advertising or promotional purposes, creating new collective works, for resale or redistribution to servers or lists, or reuse of any copyrighted component of this work in other works.

Limitations in Applying the Existing LISN Topologies for Low Frequency Conducted Emission Measurements and Possible Solution

Lu Wan

DEIB

Politecnico di Milano

Milan, Italy

lu.wan@polimi.it

Arun Khilnani

GGIEMR

University of Nottingham

Nottingham, The UK

arun.khilnani@nottingham.ac.uk

Abdusalam Hamid

DEIB

Politecnico di Milano

Milan, Italy

abdusalamhamid.beshir@polimi.it

Flavia Grassi

DEIB

Politecnico di Milano

Milan, Italy

flavia.grassi@polimi.it

Giordano Spadacini

DEIB

Politecnico di Milano

Milan, Italy

giordano.spadacini@polimi.it

Sergio Pignari

DEIB

Politecnico di Milano

Milan, Italy

sergio.pignari@polimi.it

Mark Sumner

PEMC

University of Nottingham

Nottingham, The UK

mark.sumner@nottingham.ac.uk

David Thomas

GGIEMR

University of Nottingham

Nottingham, The UK

david.thomas@nottingham.ac.uk

Abstract—The use of power electronic converters to interface renewable sources and intelligent loads to electricity distribution systems is increasing at a rapid rate as they bring flexibility and control to the system. However, they also bring an increased level of conducted emissions (CE) to the system due to their switching behaviour - usually at a few tens of kilohertz. The increased emissions are seen particularly in the low-frequency range (2-150 kHz) and it may possibly impair the operation of information and communication technology (ICT) equipment connected to the same system. It is therefore essential to assure accurate measurement of low frequency emissions from a particular piece of equipment, to ensure it meets standards for electromagnetic compatibility (EMC). According to EMC standards, CE are usually measured by using a Line Impedance Stabilization Network (LISN). However, the standard LISN bandwidth does not fully cover this low-frequency range (2-150 kHz), resulting in inaccurate measurement and poor repeatability. This paper examines this issue, by investigating the limitations in using the CISPR 16-1-2 LISN topology for CE measurement at low frequency in a grid-tied inverter system, and by proposing a possible solution, which requires adding extra components to the LISN circuit.

Index Terms—LISN, conducted emissions, low frequency, electromagnetic interference

I. INTRODUCTION

The increasing use of renewable energy sources such as photovoltaic panels and wind generators had led to a significant increase in the number of power electronic converters connected to the electricity grid, and this in turn has led to an increase in the electromagnetic interference (EMI) in modern power systems, [1]–[3]. The EMI between 2-150 kHz is especially accentuated, since the switching frequency of high power inverters is still limited to several kHz [4], [5]. However, this frequency range is not covered either by Power Quality or EMC standards, where Power Quality ranges from

50 Hz to the 40th harmonics (2 kHz) only, and EMC is considered from 9 kHz or 150 kHz up to 30 MHz [6]–[8]. This lack of regulation can result in compatibility issues between renewable energy systems and ICT devices, and also introduces problems into the measurement of emissions. For instance, the operating frequency of a LISN typically specified in EMC Standards does not fully cover the 2-150 kHz range (the frequency range for CISPR 22 and CISPR 16 are from 150 kHz- 30 MHz and from 9 kHz- 30 MHz, respectively).

Within its specified frequency range, a LISN can provide a stable input impedance for CE measurement in spite of variations of the mains impedance. The LISN acts as Low Pass Filter (LPF) to ensure that the power (AC or DC) is transferred to the load device yet uncoupling the measuring receiver from the high-frequency noise coming from the main utility supply. In this way, only the CE exiting the device under test (DUT) are measured at the LISN over the specified frequency range [9]. However, for frequencies outside the LISN bandwidth (here frequencies below 9-150 kHz are of interest), the aforesaid LISN features are not guaranteed. Hence, applying existing LISNs to measure CE levels outside this frequency range may lead to unpredictable and unrepeatability results. CE measurement below 9 kHz has not received much attention so far in the wider literature, and well designed LISN devices for this frequency range are still not commercially available. This paper aims to analyse the shortcomings in existing LISN topologies when used for measuring conducted emissions from power converters at these low frequencies and also to propose a possible solution for LISN design.

II. LIMITATIONS OF EXISTING LISNS

The first limitation is that the LISN impedance can exhibit unexpected deviations depending on the mains impedance be-

Fig. 1: LISN topologies specified in CISPR 16-1-2: (a) $50 \mu\text{H} \parallel 50 \Omega$ and (b) $(50\mu\text{H}+5\Omega) \parallel 50 \Omega$.

low the specified operating bandwidth. For instance, the EMC Standards, such as CISPR 16, CISPR 22 and FCC, specify the LISN topology in Fig. 1(a) for the use in Band B (150 kHz-30 MHz). The LISN impedance (both magnitude and phase) seen by the DUT is defined as a $50 \mu\text{H}$ inductor in parallel with a 50Ω resistor: $(50 \mu\text{H} \parallel 50 \Omega)$ plotted as Std. Band B in Fig. 2). The CISPR 16-1-2 standard allows 20% tolerance for the magnitude and $\pm 11.5^\circ$ for the phase. However, if the mains impedance changes, the overall impedance seen from the DUT outlets may exhibit significant variations below 150 kHz (see Fig. 2, where this impedance is plotted for different values of the impedance of the mains). Similarly, the topology in Fig. 1(b) is used in Band A (9 kHz-150 kHz), where the LISN impedance is defined as $(50\mu\text{H}+5\Omega) \parallel 50 \Omega$ (Std. Band A in Fig. 3). This topology usually can satisfy the requirement in Band B as well, which makes it usable for both bands, i.e., from 9 kHz to 30 MHz. Similar to the $50 \mu\text{H} \parallel 50 \Omega$ topology, this one also cannot provide stable impedance against a varying mains impedance below 9 kHz.

The unstable impedance at low frequency can be explained by inspecting the LISN topology. For instance, in Fig. 1 (b), on the one hand, the $(50\mu\text{H}+5\Omega) \parallel 50 \Omega$ LISN impedance is defined by L_1 , C_1 , R_1 , R_3 and R_4 , which exhibits approximately response as $(50\mu\text{H}+5\Omega) \parallel 50 \Omega$ at high frequency. However, at low frequency, the $0.25 \mu\text{F}$ capacitance of C_3 does not show a negligible impedance. On the other hand, the parameters L_2 , C_2 and R_2 works as a LPF to suppress the spurious mains signals and to insulate the mains impedance variations. However, this LPF does not sufficiently work well at low frequency.

The other two limitations at low frequency are: 1) insufficient isolation between the mains port and the receiver port, which can allow spurious signal to influence CE measurement and, 2) the CE from the DUT port to the receiver port are

Fig. 2: Impedances of $50 \mu\text{H} \parallel 50 \Omega$ LISN under different power grid impedance.

Fig. 3: Impedances of $(50\mu\text{H}+5\Omega) \parallel 50 \Omega$ LISN under different power grid impedance.

attenuated significantly, which limits CE assessment at low frequency. These two limitations can be associated with the Decoupling Factors (DF) and the Voltage Division Factor (VDF) defined in CISPR 16-1-2 [9]. First, a minimum isolation (DF) between each mains terminal and the LISN receiver port for a given termination (specified as 50Ω resistor in CISPR 16-1-2) of DUT port shall be met, so to ensure the following two functions of the LISN at any test frequency: 1) isolation of the unknown mains impedance to prevent its influence on CE measurement, and 2) suppression of unwanted spurious signals existing on the mains side. The minimum 40 dB DF is required above 50 kHz and requirement from 9 kHz to 50 kHz rises linearly with the logarithm of frequency (as plotted in Fig. 4 in dot blue lines). Second, the VDF is defined as the voltage ratio between DUT port and the LISN receiver port (terminated with a 50Ω load), which needs to be taken into account when CE are measured. In Fig. 4, both factors of

Fig. 4: Decoupling factor and voltage division factor of $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ LISN and augmented LISN.

the original $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ LISN are plotted (blue and red curve). Fig. 4 highlights the necessity to increase the DF and reduce the VDF at low frequency, in order to suppress further the spurious noise at low frequency from the mains side and better decouple the disturbance voltage from DUT port to receiver port below 9 kHz, respectively.

III. CE MEASUREMENT OF INVERTER SYSTEM

In order to investigate the aforesaid limitations in CE measurement, the virtual test setup shown in Fig. 5 was built in SPICE, wherein the DUT is the three-phase inverter system connected with a PV panel working at 5 kHz switching frequency. The power grid is emulated using 50 Hz three-phase voltage sources and the mains impedance as 0.2 mH inductor in series with a 1 Ω resistor. It is worth mentioning that both functional aspects and parasitic components are considered in the SPICE model. The frequency spectrum is evaluated through Fast Fourier Transforms from the time-domain simulation results.

In Fig. 6, the CE spectra obtained by using the two LISNs in Fig. 1 are compared from 2 kHz to 1 MHz. It results that the evaluated CE above 70 kHz are identical for both LISN topologies. Conversely, at low frequency, the CE evaluated by two LISNs show significant discrepancies. This phenomenon can be ascribed to the LISN impedance which is highly influenced by the mains impedance outside the LISN bandwidth, as shown in Fig. 2 and Fig. 3. It is worth mentioning that, although the $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ LISN can be used to assess CE above 9 kHz, in this application, the fundamental switching frequency (5 kHz) falls below the bandwidth, thus the obtained results at 5 kHz cannot be regarded as valid due to its dependence on the test setups (mains impedance).

To illustrate the insufficient isolation provided by the LISN at low frequency, another similar test setup exploiting only $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ LISN was simulated by SPICE in the presence and absence of spurious noise from the mains. For each mains phase, the disturbance contains 20 voltage sources

Fig. 5: Setups of CE measurement of grid-tied three-phase inverter system using existing LISN.

Fig. 6: CE of one phase of inverter system using $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ and $50\mu\text{H} \parallel 50\Omega$ LISN.

with 0.1 V amplitude each in series, from 2.5 kHz and its harmonics until 50 kHz. The measured CE in both cases are plotted in Fig. 7, the case with disturbance shows that the LISN cannot effectively suppress the mains noise below 20 kHz, thus implying spurious emission peaks in the measured CE.

IV. POSSIBLE SOLUTION

To improve the characteristics of the $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ LISN at low frequency three goals must be achieved: 1) keeping the LISN impedance stable at low frequency in spite of variations of the mains impedance, 2) increasing the DF further to suppress the noise from the mains, and 3) improving the coupling of CE at DUT side above certain frequency to the receiver port. To this end, two adapting breakout boxes containing a LPF and a high-pass filter (HPF), respectively, are attached at the mains side and output side of the LISN, respectively, as shown in Fig. 8.

The HPF breakout box has the cutoff frequency at 1 kHz using 3.3 μF capacitor (C_{HPF}) and 1 k Ω resistor (R_{HPF}), so as to have smaller VDF at low frequency (shown as red dash curve) in Fig. 4. Thus CE above 1 kHz from the DUT can be recorded using this HPF breakout box. The attached LPF can not only mask the variations of the mains impedance at low frequency, but also increase the DF to suppress the spurious signals at mains side. For instance, using 400 μH inductor

Fig. 7: CE measurement of one phase of inverter system using $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ LISN in the presence and absence of the disturbance from grid.

Fig. 8: Adapting LPF and HPF breakout boxes based on $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ LISN.

(L_{LPF}), $60\mu\text{F}$ capacitor (C_{LPF}) and 5Ω resistor (R_{LPF}) along with the aforesaid HPF breakout box for augmentation of the $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ LISN, the characteristics and the aforementioned three limitations can be improved as shown in Fig.4 and Fig. 9. First, the augmented LISN impedance is stable above 2 kHz in spite of variations of the mains impedance. The largest variation from 2-150 kHz is less than 2 dBΩ at 2 kHz (except the open and short cases). Second, the DF is increased and VDF is decreased at low frequency compared with the original LISN. It is worth noting that by reducing further the cutoff frequency of the LPF breakout box, better characteristics can be achieved from 2 kHz. However, this action represents a tradeoff between better characteristics and other requirements. For instance, the bulky inductor in the LPF has a low self-resonance frequency due to the inherent parasitic capacitor, which limits the upper operating frequency of the LISN. Moreover, the leakage current of the capacitor in the LPF should be limited by using several capacitors in parallel and a resistor in series with each capacitor.

V. CONCLUSIONS

This paper has investigated the three main limitations of using traditional LISNs for CE measurement starting from 2 kHz. These are 1) its unstable impedance under variations of

Fig. 9: Impedance of augmented $(50\mu\text{H}+5\Omega) \parallel 50\Omega$ LISN.

the supply utility impedance, b) its weak provision for isolation between the utility and the DUT, and c) the poor coupling of the DUT to the receiver port at low frequencies. These limitations are illustrated by simulating the CE measurement in a grid-tied three-phase inverter system. Finally, a possible solution is proposed which adds circuit elements to the existing LISN topology to improve its low frequency performance.

REFERENCES

- [1] R. Araneo, S. Lammens, M. Grossi, and S. Bertone, "Emc issues in high-power grid-connected photovoltaic plants," *IEEE Transactions on Electromagnetic Compatibility*, vol. 51, no. 3, pp. 639–648, 2009.
- [2] G. Rietveld, D. Hoogenboom, and M. Acanski, "Conducted emi causing error readings of static electricity meters," in *2018 Conference on Precision Electromagnetic Measurements (CPEM 2018)*, 2018, pp. 1–2.
- [3] J. B. Noshahr and B. M. Kalasar, "Evaluating emission and immunity of harmonics in the frequency range of 2–150 kHz caused by switching of static converter in solar power plants," *CIREN-Open Access Proceedings Journal*, vol. 2017, no. 1, pp. 625–628, 2017.
- [4] D. Darmawardana, S. Perera, D. Robinson, P. Ciufio, J. Meyer, M. Klatt, and U. Jayatunga, "Investigation of high frequency emissions (supraharmonics) from small, grid-tied, photovoltaic inverters of different topologies," in *2018 18th International Conference on Harmonics and Quality of Power (ICHQP)*, 2018, pp. 1–6.
- [5] S. Rönnerberg, M. Bollen, and A. Larsson, "Emission from small scale pv-installations on the low voltage grid," in *The Renewable Energies and Power Quality Journal (RE&PQJ)*, no. 12, 2014.
- [6] S. K. Rönnerberg, M. H. Bollen, H. Amaris, G. W. Chang, I. Y. Gu, L. H. Kocewiak, J. Meyer, M. Olofsson, P. F. Ribeiro, and J. Desmet, "On waveform distortion in the frequency range of 2 kHz–150 kHz—review and research challenges," *Electric Power Systems Research*, vol. 150, pp. 1–10, 2017.
- [7] S. Subhani, V. Cuk, and J. Coben, "A literature survey on power quality disturbances in the frequency range of 2–150 kHz," in *Proceedings of the International Conference on Renewable Energies and Power Quality (ICREPQ'14)*, Málaga, Spain, 2017, pp. 4–6.
- [8] J. Meyer, V. Khokhlov, M. Klatt, J. Blum, C. Waniek, T. Wohlfahrt, and J. Myrzik, "Overview and classification of interferences in the frequency range 2–150 kHz (supraharmonics)," in *2018 International Symposium on Power Electronics, Electrical Drives, Automation and Motion (SPEEDAM)*, 2018, pp. 165–170.
- [9] CISPR16-1-2, "Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-2: Radio disturbance and immunity measuring apparatus - Coupling devices for conducted disturbance measurements," International Electrotechnical Commission, Standard, 2014.